DIAL POST VILLAGE HALL ASSOCIATION



Margaret Childs Treasurer 0845 157 0051 Alan Childs Chairman 01403 710388 Peter Whale Secretary 01403 710670 **Registered Charity Number: 228655**

Dial Post Village Hall Worthing Road Dial Post West Sussex RH13 8NS

www.dialpostvillagehall.co.uk

Fire Safety Risk Assessment

Fire Safety Risk Assessment - Dial Post Village Hall

Headings	Potential Fire Hazard Areas	Comments & Actions
1. Identify Fire Hazards	Electrical Heating & Lighting	The Fire Alarm system, (which comprises of detectors in all areas), is checked weekly and all Emergency Lights are checked monthly.
	Timber Framed Building	New Build 2009. Electrical Test was carried out Jan 2010.
		All external wood has been treated with fire retardant chemicals. Fire retardant insulation in all walls.
	Cooker	Fire Blanket and First Aid Kit are located adjacent to cooker.
2. Identify People at Risk	Users are easy to evacuate through four wide exit doors to Assemble Point in car park.	Inside exit routes are clearly identified.
		Outside-exits are lit with emergency lights.
	Disabled people can leave by though the two front doors and via the disabled ramp at the rear.	In the event of a power cut, the emergency lights come on for a minimum of 3 hours.
	Children are always to be accompanied by adults.	Disabled toilet has an emergency pull cord and is also fitted with an emergency light.
3. Evaluate & Deal with Risks	Fire Equipment- There are Fire Extinguishers in the Kitchen, Foyer and Lobby.	Weekly – fire equipment visually inspected and tested
	Fire blanket and first aid Kit in kitchen	Monthly, emergency lights and exit
	Smoke/Heat detectors located in all areas	doors inspected and tested.
	All exits are kept clear.	
4. Record. Plan, Inform, etc	Plan of equipment included on Village Hall booking form and on display on the Foyer wall.	
	Users informed of exits and fire procedures at the beginning of events.	
5. Review	Annually-before AGM	